

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE 1 OF 2 PAGES
2. AMENDMENT/MODIFICATION NO. ONE (1)	3. EFFECTIVE DATE See Block 16C.	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable)	
6. ISSUED BY NASA/Goddard Space Flight Center Greenbelt, MD 20771		7. ADMINISTERED BY (If other than Item 6)		
8. NAME AND ADDRESS OF CONTRACTOR (No. Street, county, State and ZIP: Code) TO ALL POTENTIAL BIDDERS		9A. AMENDMENT OF SOLICITATION NO. NNG13412656E		
		9B. DATED (SEE ITEM 11) November 01, 2012		
		10A. MODIFICATION OF CONTRACT/ORDER NO.		
		10B. DATED (SEE ITEM 13)		
CODE		FACILITY CODE		

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended, ☒ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning one (1) copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATA SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and data specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

<input type="checkbox"/>	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
<input type="checkbox"/>	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
<input type="checkbox"/>	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
<input type="checkbox"/>	D. OTHER Specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is not, ☐ is required to sign this document and return ____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

This amendment to IFB NNG13412656E – Construction of the Flight Projects Building is hereby issued to revise sections of the Division Specifications.

See page 2 for the details.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) Kathleen M. Pierson	
15B. CONTRACTOR/OFFEROR <i>(Signature of person authorized to sign)</i>	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY <i>//signed//</i> <i>(Signature of Contracting Officer)</i>	16C. DATE SIGNED Nov 05, 2012

1. The following Division Specification Sections are hereby revised as follows:
 - a. Section 23 22 26.00 20 – Disregard all references to copper piping and fittings in section 23 22 26.00 20. Copper piping and fittings will not be acceptable for use with low pressure steam condensate systems.
 - b. Section 23 64 26 – Type M copper piping and fittings will not be acceptable for use with above ground chilled water piping systems. Above ground copper chilled water systems shall use Type L copper only.
 - c. Section 22 00 00 – Type M copper piping and fittings will not be acceptable for use with above ground potable water piping systems. Above ground copper potable water piping systems shall use Type L copper only with soldered or brazed joints.
 - d. Section 23 21 13.00 20 – Above ground copper low temperature heating water piping systems may use Type L copper in lieu of the Type K indicated. Flared or compression copper joints or fittings will not be acceptable. Soldered or brazed joints for these pipes and fittings will be required.

Bidders must acknowledge receipt of this amendment prior to the hour and date specified in the Invitation for Bid by one of the following methods: (a) By completing Items 8 and 15, and returning one (1) copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the bid submitted; or (c) By separate letter or telegram which includes a reference to the bid and amendment number.

**FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE
DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATA
SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER**

[End of Amendment 1]